



**spelstormwater**

**6000 Series**

# **Spel Ecoceptor®**

**In-line Gross Pollutant Trap**



[spel.com.au](http://spel.com.au)

# CONTENTS

Introduction 1

Important 1

Safety Precautions 1

Procedure for Installation 2

After Installation 2

Typical Installation Drawing 3

Maintenance 4

Warranty 5

# INTRODUCTION

Congratulations on your purchase of a SPEL ECOCEPTOR. With proper care and by following a few simple guidelines your system will give you many years of dependable service.

## IMPORTANT

Only qualified personnel should install, operate and repair your ECOCEPTOR. Before installation local authorities must be consulted for all applicable codes and regulations.

## SAFETY PRECAUTIONS

1. Ensure installer is aware of “Confined Spaces” guidelines.
2. Make sure that there is sufficient oxygen and that there are no poisonous gases present.
3. Check the explosion risk before welding or using electric hand tools.
4. Do not ignore health hazards. Observe strict cleanliness.
5. Ensure that the lifting equipment (where required) is in good condition.
6. Keep a first aid kit handy.

### 7. Lifting and handling instructions

Palletised tanks can be safely removed from the truck using a forklift. All other tanks should be removed from the truck using the designated lifting lugs.

For large-diameter tanks, a spreader bar and lines to appropriate lifting lugs, or a clevis and lines to lifting lugs shall be used to unload tanks shipped on a flat bed trailer.

The angle between the lifting lines and top of tanks must always be 60 degrees or greater. When lifting lugs are not provided, tanks should be lifted off using two canvas or nylon slings or straps and a spreader bar which is attached to the hoist cable.

Large tanks should be righted, by hoisting with spreader bar and lines to the lifting or clevis and lines of lifting lugs. Adequate padding is necessary to protect the pivot point.

Workmen should keep control over the tank with guidelines to insure the tank is gently brought to rest upon its base.

Use a spreader bar and lines or clevis lines to appropriate lift lugs to move tank when in an upright position. Insure size of lifting equipment, lines, and clevises are capable of handling the weight of the tank.

# PROCEDURE FOR INSTALLATION

See “Typical Installation” – Page 3


1. The excavation for the tank should be no greater than 250mm to 300mm oversize to tank diameter, with due regard to the amount of concrete or backfill to be used under and around the tank.
2. It is suggested that the base of the tank be drained, especially in water charged ground, before, during and until concrete encasement has set, to hold the tank securely in the ground.
3. Lay a minimum of 100mm of 20mpa concrete slurry in base of excavation.
4. Lower tank into excavation while concrete is still a slurry. Ensure no rocks or sharp objects fall into the excavation as damage to the tank wall and base could occur.
5. Where locking holes are provided in the base of the tank, fit reo bar so it penetrates the concrete slurry to stop the tank base moving.
6. Level and adjust tank to suit installation conditions.
7. Fill tank water up to the first rib or at least 300mm – 400mm depth.
8. Secure tank with stabilising bars or timbers to hold in place before encasing with concrete.
9. The tanks are provided with a collar approximately 300mm from the base. The purpose of this collar is to create a bond between the tank and the backfill material to withstand the upward forces when the tank is empty.
10. Check local council and other authorities requirements concerning levels. Ensure you have relevant inspectors approval before backfilling commences.
11. Whilst site conditions will determine the amount of concrete encasement, you should refer to engineers instructions for each individual site.
12. Backfill material must not exceed 100mm to underside of lid when fitted with gatic type concrete in-fill lid.
13. When backfilling use sand or soil only. At all times be careful that rocky or sharp objects are not used. Avoid use of heavy soils that do not consolidate.
14. All pipe connections to tank must be sealed to stop water and dirt ingress.

# AFTER INSTALLATION

1. Ensure that the tank is protected from accidental contact by motor vehicles, construction or farm equipment or wandering livestock.
2. Where there is danger of stock being able to walk on the lid, the tank must be fenced to prevent the risk of the lid being pierced or injury to livestock. Alternatively, a specially constructed lid able to withstand the required traffic can be supplied, it is preferable for this to be specified prior to installation.

# TYPICAL INSTALLATION DRAWING

Installation procedures may vary from site to site and with different model tanks. Please read installation instructions carefully. If in doubt refer to Engineers Department.



# MAINTENANCE

## INSPECTION AND CLEANING

The regularity of inspections of the SPEL ECOCEPTOR 6000 SERIES is contingent on the features and properties of the catchment area.

SPEL recommends an inspections of the ECOCEPTOR 6000 SERIES at the end of the first month after installation to determine the volume of trapped silt and pollutants.

Information sourced can be useful in factoring the frequency of on-going inspections or cleaning operations.

In the event of excessive rain or an oil spill, an inspection is recommended immediately upon such an event.

Ascertain silt depth and if build-up is evident, then a vacuum-loader truck should be engaged for the cleaning of the tank.

SPEL ECOCEPTOR 6000 SERIES cleaning procedure is simple, by simply lifting the external lid (two persons may be required), resting it securely in a safe manner and then inserting suction hose into the chamber.

**Ensure that the chamber is thoroughly cleaned of all refuse and debris before accessing the chamber - if required.**

The chamber is cleaned by inserting the suction hose through the manhole at ground level.

Always commence cleaning from the inlet side of the chamber and ensure on completion of the cleaning operation that the lid is secured to its normal position (and locked if necessary) before departing the site.

## IMPORTANT

In the unlikely event of the chamber having to be entered ensure absolutely that all Workplace Health and Safety directives and Confined Space Regulations are strictly adhered to, including wearing long-arm rubber gloves and the appropriate footwear in the event of coming into contact with sharp objects.

## CAUTION: ALWAYS BE AWARE OF SYRINGES AND NEEDLES

# WARRANTY

The **ECOCEPTOR** manufactured by **SPEL Stormwater PTY LTD** are guaranteed to be free from defects in material or workmanship for one year from the date of shipment from factory in Parramatta.

No claim will be recognised for any alleged defects in tanks that may have been apparent prior to installation, whether due to faults in manufacture or faults caused by transports handling.

The obligation of this warranty, statutory or otherwise, is limited to replacement or repair at Parramatta factory or at a point designated by **SPEL Stormwater**, of such part as shall appear to us, upon inspection at such point, to have been defective in material or workmanship.

This warranty does not obligate **SPEL Stormwater** to bear the cost of labour or transportation charges in connection with replacement or repair of defective parts; not shall it apply to a tank upon which repairs or alterations have been made unless authorised by **SPEL Stormwater** in writing.

No express, implied or statutory warranty, other than herein set forth is made or authorised to be made by **SPEL Stormwater**.

In no event shall **SPEL Stormwater** be liable for consequential damages or contingent liabilities arising out of the failure of any **SPEL ECOCEPTOR** or parts thereof to operate properly.

**SPEL Environmental** is not responsible for losses, injury or death resulting from a failure to observe safety precautions set out herein, or misuse or abuse of pumps or related equipment.

A properly completed Warranty Registration form must be on file at the **SPEL Stormwater** office in order to activate your warranty.

If you have a claim under the provisions of the warranty, contact your local SPEL distributor.

When contacting your representative for service, please forward the following details.

Please fill in and keep this information and return enclosed warranty card.

Invoice No.: \_\_\_\_\_ Client's name: \_\_\_\_\_

Tank Model No.: \_\_\_\_\_ Job No.: \_\_\_\_\_

Installed by: \_\_\_\_\_ Date: \_\_\_\_\_



100 Silverwater Rd, Silverwater NSW 2128 Australia

**Phone:** (02) 8705 0255

**Fax:** (02) 8014 8699

**Email:** [sales@spel.com.au](mailto:sales@spel.com.au)

**[spel.com.au](http://spel.com.au)**

SPEL Stormwater accepts no responsibility for any loss or damage resulting from any person acting on this information. The details and dimensions contained in this document may change, please check with SPEL Stormwater for confirmation of current specifications.